



**TO : MRS. ANGIE MOTSHEKGA
MINISTER OF BASIC EDUCATION**

**FROM: MR H. A. LESUFI
MEMBER OF EXECUTIVE COUNCIL
EDUCATION**

DATE: 18 MAY 2020

SUBJECT: QUESTION POSED BY THE NATIONAL ASSEMBLY NA733

Please find responses to questions posed by the National Assembly, for your consideration:

Mr M S F de Freitas (DA) to ask the Minister of Basic Education:

QUESTION 1:

By what date will her department construct additional learner ablution facilities at the Hill High School in Johannesburg?

ANSWER:

The Department does not plan to build additional learner ablution facilities at the Hill High School.

Annexure G of the Regulations Relating to the Minimum Uniform Norms and Standards for Public School Infrastructure determines the number of toilets required at school. The school has an enrolment of 1 339 learners and in terms of the Regulations, the school requires 16 toilet seats for girls, 8 seats for boys and urinals that can accommodate 8 boys.

The existing toilets at the school are 20 seats for girls, 14 for boys and the urinals can comfortably accommodate 8 boys. Therefore, the school does not have a shortage of learner ablution facilities.

QUESTION 2:

What number of facilities will be constructed for each gender?

ANSWER:

Please see (1) above.

QUESTION 3:

What are the (i) dates, (ii) deadlines, (iii) milestones and (iv) time frames in each case?

ANSWER:

Please see (1) above.

QUESTION 4:

Why have the additional facilities not been built to date?

ANSWER:

Please see (1) above.


QUESTION 5:

(i) What total amount has her department allocated towards the project and (ii) from which budget has the specified amount been allocated?

ANSWER:

Please see (1) above.

Kind Regards,



MR ANDREK (PANYAZA) LESUFI, MPL
MEMBER OF EXECUTIVE COUNCIL: EDUCATION

DATE: 25/05/2020